



Republic of the Philippines
ZAMBOANGA CITY WATER DISTRICT
Pilar Street, Zamboanga City

Addendum No. 2018-040

This Addendum is issued to modify or amend the Bid Documents in view of the Pre-Bid Conference last **October 9, 2018**. This shall form an integral part of the Bid Documents. The Bids & Awards Committee hereby issues the following amendments, clarifications & updates:

PR No.	Item Description	Issues/Amendments/Updates/Clarifications for the particular Purchase Requisition
18-0260	Supply & Delivery of Rapid Test Kit for Total Coliform/E. Coli (100 Spls) for laboratory use	<ul style="list-style-type: none">• Complete set of accessories except incubator• For Total and E. Coli Test for drinking Water based on the detection of B-D galactosidase and B-glucoronidase enzyme using chromogenic and flurogenic substrate in just 18 hours• Must be DOH approved Product• Expiration Period of Chemicals in Rapid Test Kit: One (1) Year from receipt of items• Please find attached revised Technical Specifications and Schedule of Requirements
18-0264	Supply & Delivery of Various G.I. Fittings for use in new tapping materials for the year 2018 to be carried in stock	<ul style="list-style-type: none">• Manufacturing Test Certificate or any equivalent document as approved by concerned authorized Philippine Government Agency or DOST-accredited laboratory. The Certificate shall be submitted during delivery as to compliance to its manufacturing quality standard.• Delivery Period: Sixty (60) calendar days• The Procuring Entity may exercise request for advance/partial delivery however, payment of which will be made after full delivery.• <u>Standard Specification:</u> Material: ASTM A 197 Cupola Malleable Iron ASTM A 153 Zinc Coating
18-0131	Supply, Delivery, Testing of One (1) Unit Brand New Mini Backhoe (Wheel Type) for TSG, use in various projects, maintenance works & related activities of the Office	

PR No.	Item Description	Issues/Amendments/Updates/Clarifications for the particular Purchase Requisition	
18-0297	Proposed Luyahan Three Phase Upgrading Project for upgrading of electrical Primary Distribution Line of Luyahan Booster Station	<ul style="list-style-type: none"> Project Name shall be revised as Supply, Installation, Testing & Commissioning of Three Phase Distribution Line of Luyahan Booster Station (Proposed Luyahan Three Phase Upgrading Project) Similar Project shall refer to Supply, Installation, Testing & Commissioning of Three Phase Primary Line/Power Transmission Line PCAB License: General Engineering with specialty on electrical projects Financial Documents shall include the following: <ul style="list-style-type: none"> Bid Form Price Schedule Bill of Quantities (BOQ) Detailed Estimates 	
		Particular	Amendments to the Technical Specifications
		Item 7.2.1 Distributing Poles The distributing poles to be provided by the Agency shall be factory made 35 Footer and 45 Footer Round Centrifugal Galvanized Steel Poles with Minimum Break Load of 500 Kgf. that shall conform to National Electrification Administration (NEA) and Local Power Co./Cooperative's Standards.	Item 7.2.1 Distributing Poles The distributing poles to be provided by the Agency shall be factory made 35 Footer and 45 Footer Round Centrifugal Galvanized Steel Poles and/or Pre-stressed Concrete Centrifugal Poles with Minimum Break Load of 500 Kgf. that shall conform to National Electrification Administration (NEA) and Local Power Cooperative's Standards.
		Item 7.3.1 Distribution Transformers No. of units: 3 KVA Rating: 25 kVA/unit Primary Voltage, KV: 7620V/13200V Secondary Voltage: 120V/230V Basic Insulation Level (BIL): 30 kV Frequency, HZ: 60 Percentage Impedance and Tolerance: 2.5% Z +/- 10% Tolerance Ambient Air Temperature: 30°C Average Winding Temperature Rise: not exceed 65 °C above ambient Hottest Winding Temperature Rise: not exceed 85 °C above ambient Insulating Liquid Temperature Rise: not exceed 65 °C above ambient Losses at No-Load: 59 Watts Losses at Full-Load: 289 Watts Average Sound Level: 54 Decibels	Item 7.3.1 Distribution Transformers No. of units: 3 KVA Rating: 25 kVA/unit Primary Voltage, KV: 7620V/13200V Y Secondary Voltage: 240V Basic Insulation Level (BIL): 30 kV Frequency, HZ: 60 Percentage Impedance and Tolerance: 2% Z +/- 10% Tolerance Ambient Air Temperature: 30°C Cooling Class: 0A Losses at No-Load: 80 Watts Losses at Full-Load: 290 Watts Average Sound Level: 48 Decibels No. of Bushings: 2 Polarity: Additive
		Item VIII. Bill of Quantities SPL-4 Final staking, boreholing and supply & installation of 35' concrete pole, class 5 SPL-5. Final staking, boreholing and supply & installation of 45' concrete pole, class 5	Item VIII. Bill of Quantities SPL-4 Final staking, boreholing and supply & installation of 35' Round Centrifugal Galvanized Steel Poles and/or Pre-stressed Concrete Centrifugal Poles SPL-5. Final staking, boreholing and supply & installation of 45' Round Centrifugal Galvanized Steel Poles and/or Pre-stressed Concrete Poles

Issues/Amendments/Updates/Clarifications to the Bidding Documents for all Purchase Requisitions stated in this Addendum	
➤	Please refer to GPPB Resolution No. 26-2017 regarding Deferment of the implementation of the mandatory submission of Philippine Government Electronic Procurement System (PhilGEPS) Certificate of Registration and Membership in Competitive Bidding
➤	As per Section 25.2. of the 2016 Revised IRR of RA 9184, the first envelope shall contain the following technical information/documents, at the least: <div> a) For the procurement of Goods: <div> i) PhilGEPS Certificate of Registration and membership in accordance with Section 8.5.2 of this IRR, except for foreign bidders participating in the procurement by a Philippine Foreign Service Office or Post, which shall submit their eligibility documents under Section 23.1 of this IRR: Provided , That the winning bidder shall register with the PhilGEPS in accordance with Section 37.1.4 of this IRR. ii) Statement of all Ongoing Government and Private Contracts; iii) Statement of SLCC; iv) NFCC Computation or committed Line of Credit; v) JVA or the Duly Notarized Statement in accordance with Section 23.1(b) of this IRR, if applicable; vi) Bid security in the prescribed form, amount and validity period; vii) Technical Specifications, which may include production/delivery schedule, manpower requirements, and/or after-sales service/parts, if applicable; viii) Omnibus Sworn Statement in accordance with Section 25.3 of this IRR; and ix) For foreign bidders claiming eligibility by reason of their country's extension of reciprocal rights to Filipinos, a certification from the relevant government office of their country stating that Filipinos are allowed to participate in their government procurement activities for the same item or product. </div> </div>

Issues/Amendments/Updates/Clarifications to the Bidding Documents for all Purchase Requisitions stated in this Addendum

- As per Section 25.4. of the 2016 Revised IRR of RA 9184, The second envelope shall contain the financial information/documents as specified in the PBDs.
- BAC shall adhere to the 2016 Revised IRR of RA 9184 and any discrepancies in the Instruction to Bidders, the 2016 Revised IRR of RA 9184 will prevail.
- Clarification(s) on any part of the Bidding Documents or for an interpretation must be in writing and submitted to the Procuring Entity at least ten (10) calendar days before the deadline set for the submission and receipt of Bids.
- All forms of bid security are acceptable however if the Bidder opts to submit a Surety Bond it must be callable on demand and must be accompanied by (1) Certificate of Authority from the Insurance Commission authorizing the Insurance/Finance Company to issue such bond and (2) another Certification for the surety bond from the Insurance Commission for bidding purpose of the specific project. A new form of bid security which is Bid Securing Declaration is acceptable, pursuant to GPPB Resolution No. 03-2012 dated January 27, 2012.
- Proper tabbing of bid documents must be observed by the bidders.
- The bidders are advised to observe the Bid Prices found in the ITB Clause 15.
- The bidders are advised to observe the Format and Signing of Bids found in the ITB Clause 19.
- The bidders are advised to observe the Sealing and Marking of Bids found in the ITB Clause 20.

For guidance and information of all concerned.



MICHAEL ANGELO M. CARBON
Chairperson
Bids and Awards Committee

Posting date: October 16, 2018
Posted in the Phil-GEPS, ZCWD Website & Bid Bulletin