




Republic of the Philippines
ZAMBOANGA CITY WATER DISTRICT
Zamboanga City

SPECIFICATIONS


1. Standard Remote Type Transmitter compatible with existing ZCWD Aquaprobe II Sensor (Insertion Type Flowmeter)
2. Compatible External Battery for the Transmitter (3.1 V-3.6 V)
3. Sensor to Transmitter Cable 10m
4. Potting Compound Kit 200g Pack per Sensor.

Note: The Item that the supplier will provide must be compatible to the The Existing ZCWD ABB Aquaprobe II Sensor (Insertion Type Flowmeter)

Prepared by:


MARK BENEDICT C. REYES
Officer-In-Charge
NWRMD

APPROVED BY:


ALEJO S. ROJAS JR.
AGM-Operations Group