


WATER METER INSERTS

Intended for Arad Water Meters with the following Specifications:


1. Designed for the measurement of cold potable water
2. Size : **1/2"Ø (DN -15mm)**
3. Class : **"B"**
4. Type : **Current – Muti-jet**
5. Body : **Brass (Copper and Zinc Alloy)**
6. Sealed Meter Register : Hermetically sealed encapsulated stainless steel register with clear and tempered high impact lens and abrasion resistant.
7. Permissible Error:
 - a. **Minimum Flow Rate:±5%**
 - b. **Transitional Flow Rate: ±2%**
 - c. **Maximum Flow Rate: ±2%**
8. Maximum Working Pressure : **10bars or 1.0Mpa**
9. Maximum Working/Liquid Temperature : **30°C or Higher**
10. Water Meter Body Length : **165mm**
11. Flow Register : **ISO 4064-1 in Cubic Meters**
Minimum of 4 Digits, Straight reading
12. Provided with **magnetic ring/shield**

Note:

Items to be delivered should be mounted on meter casing/body with meter numbers clearly and permanently engraved in series.


HANLEY T. ALBAÑA
Division Manager A – PMMD


DAVID C. CAPOPEZ *7-26-19*
Division Manager A - WMMD


REYNALDO R. CABILIN
Officer In-Charge, Administration Group