



Republic of the Philippines
ZAMBOANGA CITY WATER DISTRICT
 Pilar Street, Zamboanga City

SUPPLEMENTAL/BID BULLETIN
ADDENDUM NO. 2019-019

This Addendum is issued to clarify, modify or amend items in the Bid Documents in view of the Pre-Bid Conference last **September 26, 2019**. This shall form an integral part of the Bid Documents.

PR No.	Item Description	Issues/Amendments/Updates/Clarifications for the particular Purchase Requisition	Issues/Amendments/Updates /Clarifications to the Bidding Documents
19-0095	Supply & Delivery of C.I. Materials for Various Capital Improvement Project (CIP) (2 nd Bidding)	<ul style="list-style-type: none"> All Gate Valves shall have a pressure rating of at least PN 16 (16 bars) 	<ul style="list-style-type: none"> ➤ Please refer to GPPB Resolution No. 26-2017 regarding Deferment of the implementation of the mandatory submission of Philippine Government Electronic Procurement System (PhilGEPS) Certificate of Registration and Membership in Competitive Bidding ➤ As per Section 25.2. of the 2016 Revised IRR of RA 9184, the first envelope shall contain the following technical information/documents, at the least: <ul style="list-style-type: none"> a) For the procurement of Goods: <ul style="list-style-type: none"> i) PhilGEPS Certificate of Registration and membership in accordance with Section 8.5.2 of this IRR, except for foreign bidders participating in the procurement by a Philippine Foreign Service Office or Post, which shall submit their eligibility documents under Section 23.1 of this IRR: Provided, That the winning bidder shall register with the PhilGEPS in accordance with Section 37.1.4 of this IRR. ii) Statement of all Ongoing Government and Private Contracts; iii) Statement of SLCC; iv) NFCC Computation or committed Line of Credit; v) JVA or the Duly Notarized Statement in accordance with Section 23.1(b) of this IRR, if applicable; vi) Bid security in the prescribed form, amount and validity period; vii) Technical Specifications, which may include production/delivery schedule, manpower requirements, and/or after-sales service/parts, if applicable; viii) Omnibus Sworn Statement in accordance with Section 25.3 of this IRR; and ix) For foreign bidders claiming eligibility by reason of their country's extension of reciprocal rights to Filipinos, a certification from the relevant government office of their country stating that Filipinos are allowed to participate in their government procurement activities for the same item or product. ➤ As per Section 25.4. of the 2016 Revised IRR of RA 9184, The second envelope shall contain the financial information/documents as specified in the PBDs. ➤ BAC shall adhere to the 2016 Revised IRR of RA 9184 and any discrepancies in the Instruction to Bidders, the 2016 Revised IRR of RA 9184 will prevail. ➤ Clarification(s) on any part of the Bidding Documents or for an interpretation must be in writing and submitted to the Procuring Entity at least ten (10) calendar days before the deadline set for the submission and receipt of Bids.
19-0102	Supply & Delivery of Valves for Various Capital Improvement Project (CIP) (2 nd Bidding)	<ul style="list-style-type: none"> Please find attached revised Technical Specifications and Schedule of Requirements 	
19-0232	Supply & Delivery of Water Meter Inserts intended for ½" ARAD Multi-Jet Meter	<ul style="list-style-type: none"> Please find attached revised Technical Specifications and Schedule of Requirements Section 18. Reference to Brand Names Specifications for the procurement of Goods shall be based on relevant characteristics, functionality and/or performance requirements. Reference to brand names shall not be allowed except for items or parts that are compatible with the existing fleet or equipment of the same make and brand, and to maintain the performance, functionality and useful life of the equipment. 	
19-0233	Supply & Delivery of 2,501 pcs of Water Meter ½" (Single Jet)	<ul style="list-style-type: none"> Other Requirements b. One (1) unit cut away sample to be submitted by the lowest bidder during post-qualification <i>(for new bidder only)</i> will be revised to b. One (1) unit cut away sample to be submitted by the lowest bidder during post-qualification <i>(for new models offered)</i> 	
19-0079	Supply & Delivery of C.I./D.I. Materials for Operations Group – WDD (2 nd Bidding)		
19-0224	Supply & Delivery of PVC Materials for Various Capital Improvement Project (CIP)		

PR No.	Item Description	Issues/Amendments/Updates/Clarifications for the particular Purchase Requisition	Issues/Amendments/Updates /Clarifications to the Bidding Documents
			<ul style="list-style-type: none"> ➤ All forms of bid security are acceptable however if the Bidder opts to submit a Surety Bond it must be callable on demand and must be accompanied by (1) Certificate of Authority from the Insurance Commission authorizing the Insurance/Finance Company to issue such bond and (2) another Certification for the surety bond from the Insurance Commission for bidding purpose of the specific project. A new form of bid security which is Bid Securing Declaration is acceptable, pursuant to GPPB Resolution No. 03-2012 dated January 27, 2012. ➤ Proper tabbing of bid documents must be observed by the bidders. ➤ The bidders are advised to observe the Bid Prices found in the ITB Clause 15. ➤ The bidders are advised to observe the Format and Signing of Bids found in the ITB Clause 19. ➤ The bidders are advised to observe the Sealing and Marking of Bids found in the ITB Clause 20.

For guidance and information of all concerned.



MICHAEL ANGELO M. CARBON

Chairperson

Bids and Awards Committee

Posting date: October 1, 2019

Posted in the Phil-GEPS, ZCWD Website & Bid Bulletin