



Republic of the Philippines
ZAMBOANGA CITY WATER DISTRICT
Pilar Street, Zamboanga City

SUPPLEMENTAL/BID BULLETIN

In response to query raised by **Mactan Rock Industries, Inc. dated October 3, 2019**, this Addendum is issued to clarify, modify or amend the Bid Documents. This shall form an integral part of the Bid Documents. The Bids & Awards Committee hereby issues the following amendments, clarifications & updates:

| Purchase Requisition No. | Description | Approved Budget Cost (ABC) |
|--------------------------|---|----------------------------|
| 19-0136 | Design, Build, Testing & Commissioning of the 4,000 cu.m. per day Sewage-Septage Treatment Plant (SSTP) | P 161,200,000.00 |

ADDENDUM NO. 2019-021

| | Particulars/Queries | Clarifications/Amendments |
|---|--|--|
| 1 | Is the contractor allowed to lower the area of the MRF Building as per 3.5.4 page 49 of performance specification which is 660 sq.m. The said area is too big for a building and we can convert the space for our STP plant instead. | The 660.00 square meter area referred to under 3.5.4 of the Performance Specifications pertains to the total land area which is allocated for the reconstruction/relocation of the MRF Building and its equipment and facilities, and not the floor area for the MRF office building alone. However, a perimeter fence covering the whole 660.00 square meter is required. The minimum requirements of the MRF Office building and its equipment are provided for under 3.5.5 of the Performance Specifications. |

For guidance and information of all concerned.

MICHAEL ANGELO M. CARBON
Chairperson
Bids and Awards Committee

Posting date: October 4, 2019
Posted in the ZCWD Website, PhilGEPS & Bid Bulletin