



Republic of the Philippines
ZAMBOANGA CITY WATER DISTRICT
Pilar Street, Zamboanga City

SUPPLEMENTAL/BID BULLETIN
ADDENDUM NO. 2020-009

In response to a query raised by The Alpha Enterprise in an email last September 10, 2020 and in view of the Pre-Bid Conference last **September 17, 2020**, this Addendum is issued to clarify provisions of the Bidding Documents. This shall form an integral part of the Bidding Documents.

PR No.	Item Description	Issues/Amendments/Updates /Clarifications to the Bidding Documents
20-0106	Supply & Delivery of Powder Chlorine (Calcium Hypochlorite) – 70% at 45 kgs/pail for water treatment use	<ul style="list-style-type: none">• <i>Delivery Period shall be revised from Forty (40) days after receipt of NTP to Fifteen (15) days after receipt of NTP</i>• <i>For documentary requirement in the technical specifications, the following must be submitted:</i><ul style="list-style-type: none">- <i>PIPAC and/or ITDI-DOST Certification certifying that the product being offered is at least 70% purity. Said Certification shall contain the brand name of the chemical being tested.</i>- <i>ISO Certificate of the product</i>- <i>Certified NSF/ ANSI 60</i><p><i>Note: Requirement of Intended National Standard CAS 7778-54-3 shall be dispensed with.</i></p>• <i>Please find attached revised Schedule of Requirements and Technical Specifications</i>• <i>Bid Opening will be held via Zoom Meeting on September 29, 2020 at 02:00 PM</i> <i>https://us04web.zoom.us/j/3574833448?pwd=dldYdTI RNkI0OGN0NDBBDQjJTOU5JUT09</i> <i>Meeting ID: 357 483 3448</i> <i>Passcode: TAa5gp</i>

For guidance and information of all concerned.


MICHAEL ANGELO M. CARBON
Chairperson
Bids and Awards Committee

Posting date: September 22, 2020
Posted in the Phil-GEPS, ZCWD Website & Bid Bulletin

Section VI. Schedule of Requirements

The delivery schedule expressed as weeks/months stipulates hereafter a delivery date which is the date of delivery to the project site.

Item Number	Description	Quantity	Total	Delivered, Weeks/Months
1	Powder Chlorine (Calcium Hypochlorite)-70% at 45kgs/pail	200 pails		
	Specifications:			
	1. Not less than 70% purity accompanied by a result from PIPAC and/or ITDI-DOST that the Brand name offered passed the % purity as required.			
	CERTIFICATIONS:			
	Standard Quality Management ISO # GB/T 19001-2016 / 19001-2015			
	Certified NSF / ANSI 60			
	Delivery Period: 15 days after receipt of NTP			
	Point of Delivery: ZCWD Water Treatment Plant, Pasonanca, Zamboanga City			

Technical Specifications

Item	Specification	Statement of Compliance
		<p>Bidders must state here either “Comply” or “Not Comply” against each of the individual parameters of each Specification stating the corresponding performance parameter of the equipment offered. Statements of “Comply” or “Not Comply” must be supported by evidence in a Bidders Bid and cross-referenced to that evidence. Evidence shall be in the form of manufacturer’s un-amended sales literature, unconditional statements of specification and compliance issued by the manufacturer, samples, independent test data etc., as appropriate. A statement that is not supported by evidence or is subsequently found to be contradicted by the evidence presented will render the Bid under evaluation liable for rejection. A statement either in the Bidders statement of compliance or the supporting evidence that is found to be false either during Bid evaluation, post-qualification or the execution of the Contract may be regarded as fraudulent and render the Bidder or supplier liable for prosecution subject to the provisions of ITB Clause 3.1(a)(ii) and/or GCC Clause 2.1(a)(ii).</p>
Item No.	Description	Quantity
1	Powder Chlorine (Calcium Hypochlorite)-70% at 45kgs/pail	200 pails
	Specifications:	
	1. Not less than 70% purity accompanied by a result from PIPAC and/or ITDI-DOST that the Brand name offered passed the % purity as required.	
	CERTIFICATIONS:	
	Standard Quality Management ISO # GB/T 19001-2016 / 19001-2015	
	Certified NSF / ANSI 60	