

## *Section VI. Schedule of Requirements*

The delivery schedule expressed as weeks/months stipulates hereafter a delivery date which is the date of delivery to the project site.

Item Number	Description	Quantity	Total	Delivered, Weeks/Months
1	Liquid Poly Aluminum Chloride (PAC)	1,500 drums		
	At 200 Liters/Drum content only			
	SPECIFICATIONS:			
	Alumina content: 9.0 – 10.6 w/w			
	Specific Gravity: 1.19 ±0.02 at 20°C			
	pH 1% Sol'n: 3.5 – 5.0			
	Turbidity: Not more than 30 NTU			
	NOTE:			
	Must submit 1 Liter sample during opening of bids.			
	Turbidity of the sample should not be more than 50 NTU after 20 days stocked			
	The submission of third-party Test Result for Liquid PAC during bid opening shall be revised as agreed during the pre-bid conference, instead it shall be submitted by the lowest calculated bidder during post-qualification.			
	The winning bidder can follow the original delivery schedules as stated in the Schedule of Requirements. However, the winning bidder shall have the option to deliver a minimum of 225 drums and a maximum of 300 drums per delivery.			
	Bidders are still required to deliver the minimum number of bags per delivery. Excess number of bags delivered shall not be deducted from the minimum bags required for the succeeding deliveries except when the remaining number of bags for the next delivery is less than the outstanding number of bags to be delivered due to previous excess deliveries.			
	Payment of Laboratory Testings per delivery at third-party laboratory Testing Center shall be borne by the supplier.			
	Delivery Period: Staggered delivery 1 <sup>st</sup> delivery: 225 drums – 30 days upon receipt of NTP 2 <sup>nd</sup> delivery: 225 drums – 70 days upon receipt of NTP 3 <sup>rd</sup> delivery: 225 drums – 110 days upon receipt of NTP 4 <sup>th</sup> delivery: 225 drums – 150 days upon receipt of NTP 5 <sup>th</sup> delivery: 225 drums – 180 days upon receipt of NTP 6 <sup>th</sup> delivery: 225 drums – 210 days upon receipt of NTP 7 <sup>th</sup> delivery: 150 drums – 240 days upon receipt of NTP			

	Point of Delivery: ZCWD Water Treatment Plant, Pasonanca, Z.C.			
--	--	--	--	--

# Technical Specifications

Item	Specification	Statement of Compliance
		<p><i>[Bidders must state here either “Comply” or “Not Comply” against each of the individual parameters of each Specification stating the corresponding performance parameter of the equipment offered. Statements of “Comply” or “Not Comply” must be supported by evidence in a Bidders Bid and cross-referenced to that evidence. Evidence shall be in the form of manufacturer’s un-amended sales literature, unconditional statements of specification and compliance issued by the manufacturer, samples, independent test data etc., as appropriate. A statement that is not supported by evidence or is subsequently found to be contradicted by the evidence presented will render the Bid under evaluation liable for rejection. A statement either in the Bidder's statement of compliance or the supporting evidence that is found to be false either during Bid evaluation, post-qualification or the execution of the Contract may be regarded as fraudulent and render the Bidder or supplier liable for prosecution subject to the applicable laws and issuances.]</i></p>
1	1,500 drums Liquid Poly Aluminum Chloride (PAC)	
	At 200 Liters/Drum content only	
	SPECIFICATIONS:	
	Alumina content: 9.0 – 10.6 w/w	
	Specific Gravity: 1.19 ±0.02 at 20°C	
	pH 1% Sol’n: 3.5 – 5.0	
	Turbidity: Not more than 30 NTU	
	NOTE:	
	Must submit 1 Liter sample during opening of bids.	
	Turbidity of the sample should not be more than 50 NTU after 20 days stocked	
	The submission of third-party Test Result for Liquid PAC during bid opening shall be revised as agreed during the pre-bid conference, instead it shall be submitted by the lowest calculated bidder during post-qualification.	
	The winning bidder can follow the original delivery schedules as stated in the Schedule of Requirements. However, the winning bidder shall have the option to deliver a minimum of 225 drums and a maximum of 300 drums per delivery.	
	Bidders are still required to deliver the minimum number of bags per delivery. Excess number of bags delivered shall not be deducted from the minimum bags required for the succeeding deliveries except when the remaining	

	number of bags for the next delivery is less than the outstanding number of bags to be delivered due to previous excess deliveries.	
	Payment of Laboratory Testings per delivery at third-party laboratory Testing Center shall be borne by the supplier.	