



Republic of the Philippines  
**ZAMBOANGA CITY WATER DISTRICT**  
Pilar Street, Zamboanga City

**SUPPLEMENTAL/BID BULLETIN**  
**ADDENDUM NO. 2021-003**

In view of the Pre-Bid Conference last **April 15, 2021**, this Addendum is issued to clarify provisions of the Bidding Documents. This shall form an integral part of the Bidding Documents.

PR No.	Item Description	Issues/Amendments/Updates /Clarifications to the Bidding Documents
21-0011	Supply & Delivery of 1,000 pcs Water Meter 12 – Single Jet for new tapping and to be carried in stock	<ul style="list-style-type: none"><li>• No changes/revision shall be made as to Technical Specifications</li></ul>
21-0012	Supply & Delivery of various Brass Fittings for new tapping and to be carried in stock	<ul style="list-style-type: none"><li>• Delivery Period: Shall be revised from 45 to 60 Calendar Days upon receipt of Notice to Proceed (NTP)</li><li>• Partial delivery is allowed as long as the delivery of all items shall be made within sixty (60) days.</li><li>• Copper content must be at least sixty percent (60%) and must be indicated in the Manufacturing Test Certificate.</li><li>• Manufacturing Test Certificate as approved by concerned authorized Philippine Gov't. Agency should be submitted during delivery as to compliance to its manufacturing quality standard.</li></ul>

For guidance and information of all concerned.

  
**VALERIE GAY Y. GUTIERREZ**  
Chairperson  
Bids and Awards Committee

Posting date: April 20, 2021  
Posted in the Phil-GEPS, ZCWD Website & Bid Bulletin