



Republic of the Philippines
ZAMBOANGA CITY WATER DISTRICT
 Pilar Street, Zamboanga City

SUPPLEMENTAL/BID BULLETIN
ADDENDUM NO. 2022-001

This Addendum is issued to clarify, modify or amend items in the Bid Documents in view of the **Pre-Conference** on **February 17, 2022** via Video Conferencing. This shall form an integral part of the Bid Documents.

PR No.	Item Description	Issues/Amendments/Updates /Clarifications to the Bidding Documents
22-0009	Supply & Delivery of Various C.I. Saddle Clamp for use in Newtapping Materials to be carried in stock	<ul style="list-style-type: none"> <i>Please find attached revised Schedule of Requirements and Technical Specifications</i>
22-0010	Supply & Delivery of P.E. Tubing for use in Newtapping Materials to be carried in stock	<ul style="list-style-type: none"> QUERY FROM MIE ORO: <i>"Yung item no. 1 sir, ano po itong 12mm sir, ISO po ito or CPS po?"</i> ANSWER OF END-USER: End user requires the ISO SDR11 for all items under PR No. 22-0010. QUERY FROM MIE ORO: <i>"Good day po Sir/Ma'am. May clarification lang kami tungkol sa specification no. VII. Digital Dot Matrix Printing. Ito po ba ay Laser Printed or Engraved (Embossed)? Kasi po yung marking namin is engraved(Embossed). Okay lang po ba kung marking namin ay engraved?"</i> ANSWER OF END-USER: Laser Marking only QUERY FROM MIE ORO: <i>"Sir/Ma'am good day for clarification po, yung 50mm if convert to inches 1 1/2 po ba ito or 2"?"</i> ANSWER OF END-USER: Conversion of 50mm to inch = 2 inches based on our requirements. <i>Please find attached revised Schedule of Requirements and Technical Specifications</i>
22-0011	Supply & Delivery of Brass Fittings for use in Newtapping Materials to be carried in stock	<ul style="list-style-type: none"> <i>Please find attached revised Schedule of Requirements and Technical Specifications</i>
22-0012	Supply & Delivery of G.I. Fittings for use in Newtapping Materials to be carried in stock	<ul style="list-style-type: none"> QUERY FROM WINCORP: <i>"May question lang po doon sa mga fittings for GI, is it I.D. or O.D.? yung mga sizes for example sa 12mm is it 1/2? question lang po doon sa 12mm, ang conversion nya into inches is 1/2? and then yung 19, 3/4?, tama sir?"</i> ANSWER OF ENDUSER: Under PR 22-0012, All G.I. Fittings sizes stated in the PR are all for inside diameter: 12mm = 1/2 inch 19mm = 3/4 inch 25mm = 1 inch 50mm = 2 inches 75mm = 3 inches

		<p>The outside diameter is now the basis for the heavy gauge of Sch.40.</p> <ul style="list-style-type: none">• <i>Please find attached revised Schedule of Requirements and Technical Specifications</i>
--	--	---

For guidance and information of all concerned.



MICHAEL ANGELO M. CARBON

Chairperson

Bids and Awards Committee

Posting date: February 23, 2022

Posted in the Phil-GEPS, ZCWD Website & Bid Bulletin