



SUPPLEMENTAL/BID BULLETIN
ADDENDUM NO. 2022-005

This Addendum is issued to clarify, modify or amend items in the Bid Documents in view of the **Pre-Bid Conference** last **April 7, 2022** via Video Conferencing. This shall form an integral part of the Bid Documents.

PR No.	Item Description	Issues/Amendments/Updates /Clarifications to the Bidding Documents
22-0034	Supply & Delivery of 3,500 bags Aluminum Sulfate – 17% for water treatment use	<ul style="list-style-type: none"> <p>• Query from McMai (Cebu) Trading Corporation: <i>“Sir, good afternoon. I have question regarding the submission of bidding documents. ‘Di ba the deadline is April 21, 2022, 2 PM. Is it necessary to submit it physically or it can be submitted through mail?”</i></p> <p>Response: The Procuring Entity still do not accept electronic (email) submission of bids. However, bidders can submit physical copies of the bidding documents through courier services for as long as it is received by the ZCWD BAC Secretariat on or before 2 PM, April 21, 2022. It is not necessary that the representative of the prospective bidder will hand carry the bidding documents.</p> <p>• Query from M&M Anastacio Trading: <i>“Regarding Single Largest Completed Contract (SLCC), if it is okay to attach one (1) contract only?”</i></p> <p>Response: Yes. As long as it is 25% of the ABC (Approved Budget Cost). It has been completed within five (5) years from April 21, 2022. The SLCC must be supported by Certificate of Inspection and Acceptance, or Official Receipt, or Sales/Charge Invoice.</p> <p>• Written Query via Email from Jedaric Chemicals Co., Inc.: <i>As per your Section VII-Technical Specification, a PIPAC Certificate or DOST ITDI together with the sample batch is required. We just talked with PIPAC Laboratory Manager Ms. Thelma, they can no longer accommodate rush request for testing due to the full load work in their laboratory; while DOST ITDI takes much longer time to process such testing at this time. With this, we would like to request to please allow other test results from other accredited PAB (Philippine Accreditation Bureau) laboratories like Chempro Laboratories, etc.</i></p> <p>Response: CHEMPRO is acceptable, accredited laboratory that conducts also lab test, analysis for chemicals like Alum Sulfate.</p>
22-0036	Supply & Delivery of 160 pails Powder Chlorine (Calcium Hypochlorite) – 70% at 45 kgs/pail for water treatment use	<ul style="list-style-type: none"> <p>• Not less than 70% purity accompanied by a result from PIPAC or DOST ITDI that the Brand name offered passed the % purity as required.</p> <p>• Query from McMai (Cebu) Trading Corporation: <i>“This is regarding the delivery period 40 days upon receipt of NTP. If</i></p>

		<p><i>ever hindi po kame maka-comply, sir, will there be any penalty for late deliveries?”</i></p> <p>Response: The winning bidder can request for an extension in writing and it must be received by the procuring entity before the expiration. The allowable number of days for extension is the <i>period of the original delivery</i>.</p> <p>Pursuant to THE 2016 REVISED IMPLEMENTING RULES AND REGULATIONS OF REPUBLIC ACT NO. 9184 (Updated as of 31 December 2021) ANNEX “D” CONTRACT IMPLEMENTATION GUIDELINES FOR THE PROCUREMENT OF GOODS, SUPPLIES AND MATERIALS Liquidated Damages 3.1 When the supplier fails to satisfactorily deliver goods under the contract within the specified delivery schedule, inclusive of duly granted time extensions, if any, the supplier shall be liable for damages for the delay and shall pay the procuring entity liquidated damages, not by way of penalty, an amount equal to one-tenth (1/10) of one percent (1%) of the cost of the delayed goods scheduled for delivery for every day of delay until such goods are finally delivered and accepted by the procuring entity concerned. The procuring entity need not prove that it has incurred actual damages to be entitled to liquidated damages. Such amount shall be deducted from any money due or which may become due to the supplier, or collected from any securities or warranties posted by the supplier, whichever is convenient to the procuring entity concerned. In case the total sum of liquidated damages reaches ten percent (10%) of the total contract price, the procuring entity concerned may rescind the contract and impose appropriate sanctions over and above the liquidated damages to be paid.</p>
22-0037	Supply & Delivery of Liquefied Chlorine Gas for use in Water Treatment	<ul style="list-style-type: none"> • Must provide tools and other appurtenances necessary for the operation, as follows: <ul style="list-style-type: none"> a) 4-pcs Cylinder Wrench Twisted-type b) 3-units tank connector, 1/4-inch diameter 2-meters length Copper Tubing with standard tank fittings at both ends. c) 3-units standard brass chlorine valve • During the first delivery it is paramount that the winning bidder shall not only send staff for delivery but also technical people knowledgeable in conducting a Refresher Course on Safety Handling for the Operators. • The winning bidder’s representative must conduct an inspection of the current set-up.

For guidance and information of all concerned.


MICHAEL ANGELO M. CARBON
Chairperson
Bids and Awards Committee

Posting date: April 13, 2022
Posted in the Phil-GEPS, ZCWD Website & Bid Bulletin