

TECHNICAL SPECIFICATIONS FOR TWO INCH WATER METERS

SPECIFICATIONS	
1. Standard	ISO 4064
2. Nominal Size	50mm
3. Meter Length	200mm
4. Meter Type	Current / Velocity (Woltman)
5. Metrological Class	B
6. Meter Body	Cast Iron, polyester coated or epoxy powder coated
7. Register	Hermetically sealed register
	High impact lens and abrasion resistant
	Meter Register in Cubic Meters
	Cubic Meters in registration – minimum of 6 digits
	Straight Reading
8. Working Condition	Maximum Working Pressure: 16 bars or higher
	Maximum Working/Liquid Temperature: 50°C or higher
9. Metrological Characteristics (Permissible Error)	a. Minimum Flow Rate: ±5%
	b. Transitional Flow Rate: ±2%
	c. Maximum Flow Rate: ±2%
10. Connection	Flanges according to ISO standard
	Number of bolt holes: 4 holes / flange
11. Meter Seal	Meter body should be properly sealed
12. Serial Numbering	Meter numbers should be in series, clearly and permanently engraved
13. Painting	Automotive finished (Tahiti blue or closer shade acceptable to the end user)
14. Meter Body Markings	Meter Size
	Flow Direction (arrow)
15. Packaging	All water meters shall include the following:
	a. Inclusion of efficiency test result per meter at the back of the lid cover.
	b. Certificate of calibration of every water meter

Prepared by:



Ronan M. Tarroza
Customer Service Officer, WMMD

Reviewed by:



Alva Marie C. Conti
OIC, WMMD

Digitally signed
by Conti Alva
Marie Camacho
Date: 2022.03.15
09:53:14+08'00'

Approved by:



Louella A. Aguilera
OIC, General Services Department

Digitally signed
by Aguilera
Louella Arsena
Date:
2022.03.15 11:
03:06+08'00'