



ZCWD BAC SUPPLEMENTAL BID BULLETIN NO. 2022-011

Subject: PR No. 22-0112 – Supply & Delivery of Various Submersible Motors, Pumps & Cables for use at Baliwasan, San Lorenzo, Tulungatung 2 & Trumata Production Well

This **ZCWD BAC SUPPLEMENTAL BID BULLETIN** is issued to clarify, modify or amend items in the issued Bidding Documents for the above-subject procurement in view of the **Pre-Bid Conference** last **August 11, 2022**, at the BAC Room, 3rd Floor, ZCWD Bldg., Pilar Street, Zamboanga City and via Zoom Video Conferencing.

AMENDMENTS

Item No.	Original	Amendments
1	(a) 5hp, single phase, 230VAC, 60Hz, 17Amps, SF; 1.15, 19.55Amax, 3450rpm (c) with 1 roll 3M Electrical & Rubber Tape & 1 pack 3M splicing kit	(a) 5Hp, single-phase, 230VAC, 60Hz, 3450 RPM (or its equivalent) (c) with 1 roll Electrical Tape & 1 roll Rubber Tape & 1 pack splicing kit
3	(a) 7.5Hp, 3-Phase, 230VAC, 60Hz, 22.9Amps, SF; 1.15, 26.4Amax, 3450rpm (b) 150mm (6") diameter. Complete with motor leads (c) with 1 roll 3M Electrical & Rubber Tape & 1 pack 3M splicing kit	(a) 7.5Hp, 3-phase, 230VAC, 60Hz, 3450 RPM (or its equivalent) (b) (100mm-150mm) 4"-6" diameter, complete with motor leads (c) with 1 roll Electrical Tape & 1 roll Rubber Tape & 1 pack splicing kit
5	(a) 10Hp, 3-Phase, 230VAC, 60Hz, 41.6Amps, SF; 1.15, 47.4Amax, 3450rpm (c) With 1 roll 3M Electrical & Rubber Tape & 1 pack 3M splicing kit	(a) 10Hp, 3-phase, 230VAC, 60Hz, 3450 RPM (or its equivalent) (c) with 1 roll Electrical Tape & 1 roll Rubber Tape & 1 pack splicing kit
6	(e) Built-in check valve. Six (6) stages with four (4) 12mmØ x 38mm SS bolt and lock washer,	(e) Built-in check valve. Five (5) or Six (6) stages with four (4) 12mmØ x 38mm SS bolt and lock washer, 3450rpm

	3450rpm	
7	(a) 15Hp, 3-Phase, 230VAC, 60Hz, 53.8Amps, SF; 1.15, 60.6Amax, 3450rpm (c) with 1 roll 3M Electrical & Rubber Tape & 1 pack 3M splicing kit	(a) 15Hp, 3-phase, 230VAC, 60Hz, 3450 RPM (or its equivalent) (c) with 1 roll Electrical Tape & 1 roll Rubber Tape & 1 pack splicing kit

These clarifications shall form an integral part of the Bidding Documents. All items, conditions and instruction to bidders specified in the Bidding Documents inconsistent with this Supplemental Bid Bulletin are hereby superseded and modified accordingly.

For guidance and information of all concerned.


MICHAEL ANGELO M. CARBON
 Chairperson
 Bids and Awards Committee

Posting date: August 17, 2022
 Posted in the Phil-GEPS, ZCWD Website & Bid Bulletin

Important Notes:

It is the responsibility of the bidder to take steps to carefully examine all of the Bidding Documents. The Procuring Entity shall not assume any responsibility regarding erroneous interpretations or conclusions by the prospective or eligible bidder out of the data furnished by the Procuring Entity.

A prospective eligible bidder must be responsible for having: 1. Taken steps to carefully examine all of the bidding documents; 2. Acknowledged all conditions, local or otherwise, affecting the implementation of the contract; 3. Made an estimate of the facilities available and needed for the contract to be bid, if any; and 4. Complied with his responsibility that it shall be the responsibility of all those who have properly secured the bidding documents to inquire and secure supplemental/bid bulletins that may be issued by the BAC (Government Procurement Manual Volume 3).

Failure to observe any of the above responsibilities shall be at the risk of the prospective bidder concerned. The Procuring Entity shall not be responsible for any erroneous interpretation or conclusions by the prospective or eligible bidders of the data it furnished (Government Procurement Manual Volume 3).