



Republic of the Philippines  
**ZAMBOANGA CITY WATER DISTRICT**  
Pilar Street, Zamboanga City

**ZCWD BAC SUPPLEMENTAL BID BULLETIN NO. 2022-015**

- Subject:** - PR No. 22-0221 – Supply & Delivery of Butterfly Valve for Rehabilitation of Transmission lines valves
- PR No. 22-0222 – Supply & Delivery of Air Release Valve for Rehabilitation of Transmission lines
  - PR No. 22-0231 – Supply & Delivery of various C.I. Fittings for Mainline Replacement Program – Phase I

This **ZCWD BAC SUPPLEMENTAL BID BULLETIN** is issued to clarify, modify or amend items in the issued Bidding Documents for the above-subject procurement in view of the **Pre-Bid Conferences** last **October 25, 2022**, at the BAC Room, 3<sup>rd</sup> Floor, ZCWD Bldg., Pilar Street, Zamboanga City and via Zoom Video Conferencing.

<b>PR No.</b>	<b>Query/Matter</b>	<b>Answer/Clarification</b>
<b>22-0221</b>	<b>Request to extend the Delivery Period</b>	<ul style="list-style-type: none"><li>• <b>Delivery Period shall be extended from sixty (60) to ninety (90) calendar days upon receipt of Notice to Proceed (NTP).</b></li></ul>
	<b>What part of the butterfly valve is stainless steel AISI 420?</b>	<ul style="list-style-type: none"><li>• <b>Drive Shaft</b></li></ul>
	<b>Size of handwheel is DN500, but the size of the butterfly valve is DN600?</b>	<ul style="list-style-type: none"><li>• <b>The Handwheel is DN350</b></li></ul>
	<b>Gearbox is ¼ tour operated or is it okay to offer full turn operated gearbox with handwheel?</b>	<ul style="list-style-type: none"><li>• <b>Full turn operated gearbox is required</b></li></ul>
	<b>Kind of Butterfly Valve; is it a double flange?</b>	<ul style="list-style-type: none"><li>• <b>Yes</b></li></ul>
<b>22-0222</b>	<b>On the specification “Provides the functions of both Air Release and Air Vacuum Valve,” is this a double orifice?</b>	<ul style="list-style-type: none"><li>• <b>Yes, it should perform dual function</b></li></ul>

**ZCWD BAC SUPPLEMENTAL BID BULLETIN NO. 2022-015**  
*Subject: PR No. 22-0221 – Supply & Delivery of Butterfly Valve for Rehabilitation of Transmission lines*  
*PR No. 22-0222 – Supply & Delivery of Air Release Valve for Rehabilitation of Transmission lines*  
*PR No. 22-0231 – Supply & Delivery of Various C.I. Fittings for Mainline Replacement Program Phase I*

	Regarding the end connection of the 25mm Air Release Valve, is it also a flange end connection or just a threaded type?	<ul style="list-style-type: none"> <li>The valve shall be flange end connection</li> </ul>
	On the specification, "Manufactured under a certified ISO 9001 quality system." Is it the Company or the product?	<ul style="list-style-type: none"> <li>Product.</li> </ul>
22-0231	<i>"Pwede po ba kame mag request ng outside diameter po ng pipe na pagkakabit ng mga flexible coupling"</i>	<ul style="list-style-type: none"> <li>Flexible must be fitted on the standard PVC pipe class 150</li> </ul>
	<i>"So, lahat po ng pipe is Class 150 po, tama po, sir?"</i>	<ul style="list-style-type: none"> <li>Reply of Engr. Ruiz: "Yes, ma'am. Sa PVC po Class 150"</li> </ul>

No. of Copies of Bidding Documents to be submitted	One (1) Original & Two (2) Copies (Copy 1 & Copy 2)
--	---

These clarifications shall form an integral part of the Bidding Documents. All items, conditions and instruction to bidders specified in the Bidding Documents inconsistent with this Supplemental Bid Bulletin are hereby superseded and modified accordingly.

For guidance and information of all concerned.

**MICHAEL ANGELO M. CARBON**  
Chairperson  
Bids and Awards Committee

Posting date: November 2, 2022  
Posted in the Phil-GEPS, ZCWD Website & Bid Bulletin

**Important Notes:**

It is the responsibility of the bidder to take steps to carefully examine all of the Bidding Documents. The Procuring Entity shall not assume any responsibility regarding erroneous interpretations or conclusions by the prospective or eligible bidder out of the data furnished by the Procuring Entity.

A prospective eligible bidder must be responsible for having: 1. Taken steps to carefully examine all of the bidding documents; 2. Acknowledged all conditions, local or otherwise, affecting the implementation of the contract; 3. Made an estimate of the facilities available and needed for the contract to be bid, if any; and 4. Complied with his responsibility that it shall be the responsibility of all those who have

**ZCWD BAC SUPPLEMENTAL BID BULLETIN NO. 2022-015**  
**Subject: PR No. 22-0221 – Supply & Delivery of Butterfly Valve for Rehabilitation of Transmission lines**  
**PR No. 22-0222 – Supply & Delivery of Air Release Valve for Rehabilitation of Transmission lines**  
**PR No. 22-0231 – Supply & Delivery of Various C.I. Fittings for Mainline Replacement Program Phase I**

properly secured the bidding documents to inquire and secure supplemental/bid bulletins that may be issued by the BAC (Government Procurement Manual Volume 3).

Failure to observe any of the above responsibilities shall be at the risk of the prospective bidder concerned. The Procuring Entity shall not be responsible for any erroneous interpretation or conclusions by the prospective or eligible bidders of the data it furnished (Government Procurement Manual Volume 3).

**ZCWD BAC SUPPLEMENTAL BID BULLETIN NO. 2022-015**  
**Subject: PR No. 22-0221 – Supply & Delivery of Butterfly Valve for Rehabilitation of Transmission lines**  
**PR No. 22-0222 – Supply & Delivery of Air Release Valve for Rehabilitation of Transmission lines**  
**PR No. 22-0231 – Supply & Delivery of Various C.I. Fittings for Mainline Replacement Program Phase I**