



Republic of the Philippines  
**ZAMBOANGA CITY WATER DISTRICT**  
Pilar Street, Zamboanga City

**ZCWD BAC SUPPLEMENTAL BID BULLETIN NO. 2022-017**

- Subject:** - PR No. 22-0239 – Supply & Delivery of Various Brass Fittings for use at leak repair & rehabilitation of service lines
- PR No. 22-0245 – Supply & Delivery of 700mmØ Sleeve Type Flexible Coupling use for the supply of 50mld transmission line
  - PR No. 22-0249 – Supply & Delivery of Various Brass Fittings for use in new tapping and to be carried in stock

This **ZCWD BAC SUPPLEMENTAL BID BULLETIN** is issued to clarify, modify or amend items in the issued Bidding Documents for the above-subject procurement in view of the **Pre-Bid Conferences** last **November 25, 2022**, at the BAC Room, 3<sup>rd</sup> Floor, ZCWD Bldg., Pilar Street, Zamboanga City and via Zoom Video Conferencing.

<b>PR No.</b>	<b>Query/Matter</b>	<b>Answer/Clarification</b>
22-0239	<i>“Sir, sa item number 6 at saka po number 10, same lang po ba ng size ‘to, sir?”</i>	<ul style="list-style-type: none"><li>• Yes, same size</li></ul>
	<i>Item no. 6 and 10 was the same sizes? 19mm (3/4”) (query via email)</i>	
	<i>“Tanong ko lang po kung yung Brass Fitting po na kailangan po ninyo is clamp type po ba or ISO or CPS po?”</i>	<ul style="list-style-type: none"><li>• <b>Clamp Type</b></li></ul>
	<i>Please specify that all brass fittings if clamp type or ISO (query via email)</i>	
	<i>“Sir, yung Brass Corporation Cock, ano ‘to, Brass Corporation Stop ba ‘to, [item] number 1 po.”</i>	<ul style="list-style-type: none"><li>• <b>Same item</b></li></ul>
<i>“Sir, ask ko lang po yung item number 15, ano ‘to 25mm siya tapos ano ‘to sir, 1X1?”</i>	<ul style="list-style-type: none"><li>• <b>25mm diameter angle valve and the connection is also 25mm or 1” diameter connection</b></li></ul>	
<i>Pictures of the following items:</i> <ul style="list-style-type: none"><li>• <b>Brass ball valve (key type)</b></li><li>• <b>Brass ball valve (wing type)</b></li><li>• <b>Brass corporation cock</b></li></ul>	<ul style="list-style-type: none"><li>• <b>Please refer to attached pictures</b></li></ul>	

**ZCWD BAC SUPPLEMENTAL BID BULLETIN NO. 2022-017**  
**Subject:** PR No. 22-0239 – Supply & Delivery of Various Brass Fittings for use at leak repair & rehabilitation of service lines  
PR No. 22-0245 – Supply & Delivery of 700mmØ Sleeve Type Flexible Coupling use for the supply of 50mld transmission line  
PR No. 22-0249 – Supply & Delivery of Various Brass Fittings for use in newtapping and to be carried in stock

	<ul style="list-style-type: none"> <li>• <i>Brass double adaptor</i></li> </ul>	
22-0245	<p>“Tanong ko lang po, Sir, kung anong pagkakabit ng STC, PVC, DI or asbestos cement po?”</p>	<ul style="list-style-type: none"> <li>• <i>Ductile Iron</i></li> </ul>
	<p>“anong convert inches po ng 700 mm?”</p>	<ul style="list-style-type: none"> <li>• 28 inches</li> </ul>
	<p>“Tanong ko lang po kung ano ang outside diameter ng DI pipe”</p>	<ul style="list-style-type: none"> <li>• 738mmOD</li> </ul>
	<p>What is the outside diameter of using pipe to compatible for said STC (query via email)</p>	
	<p>What is body made for the Sleeve type flexible coupling. This will be Ductile Iron (Coated Blue or Cast iron Coated Black?)</p>	<ul style="list-style-type: none"> <li>• Cast iron (regardless of the coated color)</li> </ul>
	<p>This STC will be using for what Pipe?</p>	Ductile Iron
<p>May we request complete specification for the said PR No. to make sure that our offer brand was not mistaken. As supplier very hard from us if not clear the specification.</p>	<p>Sleeve Type Flexible Coupling Specifications:</p> <ol style="list-style-type: none"> <li>1. It shall be in compliance with AWWA C219 Standard or other worldwide known standards.</li> <li>2. Its outside diameter shall be compatible with the 700mm Ductile Iron Pipes, ISO 2531 C40 Standard having at least 16 bar pressure conveying potable water.</li> <li>3. Coupling followers and middle ring (or sleeve) may be either Iron or Steel.</li> <li>4. Bolts shall be in accordance with AWWA C111/ANSI A21.11</li> <li>5. Coating shall be fusion-bonded epoxy.</li> <li>6. Sleeve thickness and length shall be at least 9.5mm (3/8”) and 406mm (16”), respectively.</li> <li>7. Gasket shall be BUNA (Nitrile Rubber)</li> </ol>	
<p>ITB Clause 5.3 For this purpose, contracts similar to the Projects shall be:</p> <ol style="list-style-type: none"> <li>a. Pipes Appurtenances</li> </ol>	<p><b>REVISED TO:</b></p> <p>ITB Clause 5.3 For this purpose, contracts similar to the Projects shall be:</p> <ol style="list-style-type: none"> <li>a. <u>Pipes Appurtenances and/or Water Service Connections Materials/Fittings</u></li> </ol>	

**ZCWD BAC SUPPLEMENTAL BID BULLETIN NO. 2022-017**

*Subject: PR No. 22-0239 – Supply & Delivery of Various Brass Fittings for use at leak repair & rehabilitation of service lines*

*PR No. 22-0245 – Supply & Delivery of 700mmØ Sleeve Type Flexible Coupling use for the supply of 50mld transmission line*

*PR No. 22-0249 – Supply & Delivery of Various Brass Fittings for use in newtapping and to be carried in stock*

22-0249	<p><i>“Sir, pwede po ba pa-send ng picture ng Brass Safety Ball valve with Key type? Item number 3 po.”</i></p>	<ul style="list-style-type: none"> <li>• Please refer to attached picture</li> </ul>
---------	-----------------------------------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------

These clarifications shall form an integral part of the Bidding Documents. All items, conditions and instruction to bidders specified in the Bidding Documents inconsistent with this Supplemental Bid Bulletin are hereby superseded and modified accordingly.

For guidance and information of all concerned.



**MICHAEL ANGELO M. CARBON**

Chairperson

Bids and Awards Committee

Posting date: December 1, 2022

Posted in the Phil-GEPS, ZCWD Website & Bid Bulletin

***Important Notes:***

It is the responsibility of the bidder to take steps to carefully examine all of the Bidding Documents. The Procuring Entity shall not assume any responsibility regarding erroneous interpretations or conclusions by the prospective or eligible bidder out of the data furnished by the Procuring Entity.

A prospective eligible bidder must be responsible for having: 1. Taken steps to carefully examine all of the bidding documents; 2. Acknowledged all conditions, local or otherwise, affecting the implementation of the contract; 3. Made an estimate of the facilities available and needed for the contract to be bid, if any; and 4. Complied with his responsibility that it shall be the responsibility of all those who have properly secured the bidding documents to inquire and secure supplemental/bid bulletins that may be issued by the BAC (Government Procurement Manual Volume 3).

Failure to observe any of the above responsibilities shall be at the risk of the prospective bidder concerned. The Procuring Entity shall not be responsible for any erroneous interpretation or conclusions by the prospective or eligible bidders of the data it furnished (Government Procurement Manual Volume 3).

**ZCWD BAC SUPPLEMENTAL BID BULLETIN NO. 2022-017**

**Subject: PR No. 22-0239 – Supply & Delivery of Various Brass Fittings for use at leak repair & rehabilitation of service lines**

**PR No. 22-0245 – Supply & Delivery of 700mmØ Sleeve Type Flexible Coupling use for the supply of 50mld transmission line**

**PR No. 22-0249 – Supply & Delivery of Various Brass Fittings for use in newtapping and to be carried in stock**

**PR NO. 22-0239 VARIOUS BRASS FITTINGS FOR USE AT LEAK REPAIR & REHABILITATION OF SERVICE LINES**

**1. 12mmØ Brass Ball valve (Key Type)**



**2. 12mmØ Brass Ball valve (Wing Type)**



**3. 19mmØ Brass Corporation Cock**



**4. 19mmØ Brass Double Adaptor**





5. 19mmØ Brass Single Adaptor







**Brass Angle Meter Valve  
19mm (Clamp Type)  
PR# 22-0249**



**Safety Valve 12mm w/  
key type  
PR# 22-0249**