



Republic of the Philippines
ZAMBOANGA CITY WATER DISTRICT
Pilar Street, Zamboanga City

SUPPLEMENTAL/BID BULLETIN
ADDENDUM NO. 01 - 23-0062
Series of 2023

This SUPPLEMENTAL BID BULLETIN is issued to clarify, modify or amend items in the issued Bidding Documents for the below subject procurement in view of the Pre-Bid Conference last April 13, 2023, at the BAC Room, 3rd Floor, ZCWD Bldg., Pilar Street, Zamboanga City and via Video Conferencing.

PR No.	Item Description	Issues/Amendments/Updates /Clarifications to the Bidding Documents
23-0062	Supply & Delivery of Air Release Valve for the Construction of New Cahumban Water System	<ol style="list-style-type: none">50MM AUTOMATIC AIR RELEASE PRESSURE VALVES<ul style="list-style-type: none"><i>The valve shall be flange end connection conforming to AWWA C207 Class D/ ISO/ PN 16 Standard.</i><i>Meets AWWA C512 requirements or EN-1074</i>The delivery period of the materials to be supplied is changed from 30 Calendar Days to 60 Calendar Days.As stated under the specifications of the 150MM PRESSURE REDUCING VALVE, FF, this shall have (0-300 psi) Oil Filled Pressure Gauge at its upstream and downstream body. <i>However, the valve itself is required to have a maximum pressure for both upstream and downstream ranging from 100psi to 300psi.</i>Drawings of accessories may include.Inspection and Test: Manufacturer's Certificate – indicating, but not limited to, Mechanical Strength test, Leak tightness, Seat tightness (subjected to low/high pressure). Hydraulic and Precision proof test

For guidance and information of all concerned.



ATTY. VINCENT F. FERNANDEZ
Chairperson
Bids and Awards Committee

Posting date: April 18, 2023
Posted in the Phil-GEPS, ZCWD Website & Bid Bulletin