



Republic of the *Philippines*  
**ZAMBOANGA CITY WATER DISTRICT**  
Pilar Street, Zamboanga City

**SUPPLEMENTAL/BID BULLETIN**  
**ADDENDUM NO. 01 - 23-0091**  
**Series of 2023**

This SUPPLEMENTAL BID BULLETIN is issued to clarify, modify or amend items in the issued Bidding Documents for the below subject procurement in view of the Pre-Bid Conference last May 23, 2023, at the BAC Room, 3<sup>rd</sup> Floor, ZCWD Bldg., Pilar Street, Zamboanga City and via Video Conferencing.

PR No.	Item Description	Issues/Amendments/Updates /Clarifications to the Bidding Documents
23-0091	Supply & Delivery of Asphalt for Mainline Replacement Program – Phase I	<ul style="list-style-type: none"><li>• <b>Content</b><ul style="list-style-type: none"><li>- 200kgs/drum</li></ul></li> <li>• <b>Inspection and Test</b><ol style="list-style-type: none"><li>1. <b>Asphalt Cement 60/70:</b> <b>Penetration and Viscosity Grade Test</b><ul style="list-style-type: none"><li>-items must pass the following:<ol style="list-style-type: none"><li>a. <i>Density test</i></li><li>b. <i>Ductility test</i></li><li>c. <i>Penetration test</i></li><li>d. <i>Viscosity test</i></li></ol></li></ul></li><li>2. <b>Emulsified Asphalt:</b> <b>Anionic and Cationic Test</b><ul style="list-style-type: none"><li>- items must pass the following:<ol style="list-style-type: none"><li>a. <i>Density test</i></li><li>b. <i>Viscosity test</i></li><li>c. <i>Ductility</i></li><li>d. <i>Ash Content</i></li></ol></li></ul></li></ol></li></ul>

For guidance and information of all concerned.

  
**ATTY. VINCENT F. FERNANDEZ**  
Chairperson  
Bids and Awards Committee

Posting date: May 26, 2023  
Posted in the Phil-GEPS, ZCWD Website & Bid Bulletin