



SUPPLEMENTAL/BID BULLETIN
ADDENDUM NO. 01 - 23-0003
Series of 2023

This SUPPLEMENTAL BID BULLETIN is issued to clarify, modify or amend items in the issued Bidding Documents for the below subject procurement in view of the Pre-Bid Conference last November 30, 2023, at the Board Room, 2nd Floor, ZCWD Bldg., Pilar Street, Zamboanga City and via Video Conferencing.

PR No.	Item Description	Issues/Amendments/Updates /Clarifications to the Bidding Documents
23-0003	Mainline Replacement Program (LGU Funded) Phase II (2 nd Bidding)	<ul style="list-style-type: none">• Technical Specifications for the Mainline Replacement Program (LGU Funded) Phase II<ul style="list-style-type: none">I. General Bidding Requirements<ul style="list-style-type: none">1.6. Other documents to be submitted <u>during post-qualification</u>:<ul style="list-style-type: none">1.6.1 The manufacturers of uPVC and Ductile Iron pipes and fittings shall have their product certified by the following:<ul style="list-style-type: none">1.6.2<ul style="list-style-type: none">1.6.2.1 Ductile Iron Pipes: ISO 2531 C or K Series / EN 545:2010 / AWWA C151 or latest equivalent;1.6.2.2 uPVC Pipes Series 8: PNS Standard, ASTM D1784 / ISO 4439 or latest equivalent; And all other standards mentioned in the material specifications herein.1.6.3 Documents that will certify the pipes, pipe material, fittings and appurtenances overseas must be authenticated by the Philippine Embassy of whichever country it may originate, unless otherwise manufactured and procured locally which must be completed with

		all the required documents and submit during post-qualification stage.
--	--	--

For guidance and information of all concerned.


ATTY. VINCENT F. FERNANDEZ
Chairperson
Bids and Awards Committee

Posting date: December 4, 2023
Posted in the Phil-GEPS, ZCWD Website & Bid Bulletin