



Republic of the Philippines
ZAMBOANGA CITY WATER DISTRICT
Pilar Street, Zamboanga City

SUPPLEMENTAL/BID BULLETIN
ADDENDUM NO. 01 - 24-0038
Series of 2024

This Addendum is issued to clarify, modify or amend items in the Bid Documents in view of the **Pre-Bid Conference** last **February 29, 2024** via Video Conferencing. This shall form an integral part of the Bid Documents.

PR No.	Item Description	Issues/Amendments/Updates /Clarifications to the Bidding Documents
24-0038	Supply & Delivery of Various G.I. Materials for Construction of New Cahumban Water System	<ul style="list-style-type: none">• Delivery Period shall be Forty-Five (45) calendar days upon receipt of Notice to Proceed (NTP)• For G.I. Pipes (PNS Heavy Gauge Std. with Steel Flange in accordance to AWWA C207 Class D, Welded on Both Ends) sizes 200mmØ and 150mmØ, the winning bidder shall supply 8units – 19mmØ x 88mm Stainless (Full Thread) Hexagonal Bolt (Type 304) with nut and washer and 6mm. thick Rubber Gasket per end of pipe flange. A single G.I. pipe (150mmØ & 200mmØ) shall have a total of 16units - 19mmØ x 88mm Stainless (Full Thread) Hexagonal Bolt (Type 304) with nut and washer and 2pcs. 6mm. thick Rubber Gasket per Pipe.

For guidance and information of all concerned.


ATTY. VINCENT F. FERNANDEZ
Chairperson
Bids and Awards Committee

Posting date: March 5, 2024
Posted in the Phil-GEPS, ZCWD Website & Bid Bulletin