



Republic of the *Philippines*  
**ZAMBOANGA CITY WATER DISTRICT**  
 Pilar Street, Zamboanga City

**SUPPLEMENTAL/BID BULLETIN**  
**ADDENDUM NO. 01 - 24-0067&24-0080**  
**Series of 2024**

This SUPPLEMENTAL BID BULLETIN is issued to clarify, modify or amend items in the issued Bidding Documents for the below subject procurement in view of the Pre-Bid Conference last April 23, 2024, at the BAC Room, 3<sup>rd</sup> Floor, ZCWD Bldg., Pilar Street, Zamboanga City and via Video Conferencing.

PR No.	Item Description	Issues/Amendments/Updates/Clarifications to the Bidding Documents
24-0067	Supply & Delivery of Various PVC Pipes for use at Leak repair & Rehabilitation of Service lines	<ul style="list-style-type: none"> <li>• Please find attached <i>revised Schedule of Requirements and Technical Specifications</i></li> <li>• QUERY: <i>What is the terms of payment for this project?</i>  <b>ANSWER:</b> Straight Payment upon final inspection and acceptance report of the inspection committee</li> <li>• QUERY: <i>Would you conduct a plant inspection? If yes, how many days and representative?</i>  <b>ANSWER:</b> Plant inspection is not required.</li> <li>• QUERY: <i>What is the series/class of the pvc pipe?</i>  <b>ANSWER:</b> PVC Pipe Class 150</li> <li>• Bid Data Sheet ITB Clause 14.1 The bid security shall be in the form of a Bid Securing Declaration, or any of the following forms and amounts:             <ol style="list-style-type: none"> <li>a. The amount of not less than 2% of ABC <u>[Thirty-One Thousand Six Hundred Twenty-Eight Pesos and 26/100 (P 31,628.26)]</u>, if bid security is in cash, cahier's/manager's check, bank draft/guarantee or irrevocable letter of credit;</li> </ol> </li> </ul>

24-0080	Supply & Delivery of Brand New Submersible Pump/Motor & Control for use as spare pumps/motors & controls for various Production Wells	<ul style="list-style-type: none"><li>• Please find attached <i>revised Schedule of Requirements and Technical Specifications</i></li><li>• This subject procurement is categorized as non-expendable supplies. The Bidder must have completed a single contract that is similar to this Project, equivalent to at least fifty percent (50%) of the ABC.</li></ul>
---------	---	--

For guidance and information of all concerned.

  
ATTY. VINCENT F. FERNANDEZ  
Chairperson  
Bids and Awards Committee

Posting date: April 29, 2024  
Posted in the Phil-GEPS, ZCWD Website & Bid Bulletin

## *Section VI. Schedule of Requirements*

The delivery schedule expressed as weeks/months stipulates hereafter a delivery date which is the date of delivery to the project site.

Item Number	Description	Quantity	Total	Delivered, Weeks/Months
1	150mmØ x 6m PVC Pipe, w/ R.R., B/S, Class 150	188 pcs.		
2	100mmØ x 6m PVC Pipe, w/ R.R., B/S, Class 150	138 pcs.		
3	75mmØ x 6m PVC Pipe, w/ R.R., B/S, Class 150	100 pcs.		
	<ul style="list-style-type: none"> <li>• Pipes shall be marked (engraved) with the following information:</li> <li>a. Manufacturer's Name</li> <li>b. Brand</li> <li>c. Nominal outside diameter, SDR Rating &amp; Pressure Rating</li> <li>d. Batch Number</li> <li>e. Year Manufactured</li> <li>f. The word "WATER" at intervals not more than 1-meter apart</li> <li>g. White engraved markings &lt;0.15mm for wall thickness of 12mm</li> </ul>			
	Delivery Period: 60 calendar days upon receipt of NTP			
	Point of Delivery: ZCWD Property Section, Motorpool, Pasonanca, Z.C.			

## Technical Specifications

Item	Specification	Statement of Compliance
		<p><i>[Bidders must state here either “Comply” or “Not Comply” against each of the individual parameters of each Specification stating the corresponding performance parameter of the equipment offered. Statements of “Comply” or “Not Comply” must be supported by evidence in a Bidders Bid and cross-referenced to that evidence. Evidence shall be in the form of manufacturer’s un-amended sales literature, unconditional statements of specification and compliance issued by the manufacturer, samples, independent test data etc., as appropriate. A statement that is not supported by evidence or is subsequently found to be contradicted by the evidence presented will render the Bid under evaluation liable for rejection. A statement either in the Bidder's statement of compliance or the supporting evidence that is found to be false either during Bid evaluation, post-qualification or the execution of the Contract may be regarded as fraudulent and render the Bidder or supplier liable for prosecution subject to the applicable laws and issuances.]</i></p>
1	188 pcs. 150mmØ x 6m PVC Pipe, w/ R.R., B/S, Class 150	
2	138 pcs. 100mmØ x 6m PVC Pipe, w/ R.R., B/S, Class 150	
3	100 pcs. 75mmØ x 6m PVC Pipe, w/ R.R., B/S, Class 150	
	<ul style="list-style-type: none"> <li>• Pipes shall be marked (engraved) with the following information:</li> <li>a. Manufacturer’s Name</li> <li>b. Brand</li> <li>c. Nominal outside diameter, SDR Rating &amp; Pressure Rating</li> <li>d. Batch Number</li> <li>e. Year Manufactured</li> <li>f. The word “WATER” at intervals not more than 1-meter apart</li> <li>g. White engraved markings &lt;0.15mm for wall thickness of 12mm</li> </ul>	