



Republic of the Philippines
ZAMBOANGA CITY WATER DISTRICT
 Pilar Street, Zamboanga City

SUPPLEMENTAL/BID BULLETIN
ADDENDUM NO. 02 - 24-0054 & 24-0055
Series of 2024

This SUPPLEMENTAL BID BULLETIN is issued to clarify, modify, or amend items in the issued Bidding Documents for the below subject procurement in view of the Pre-Bid Conference last April 30, 2024, at the BAC Room, 3rd Floor, ZCWD Bldg., Pilar Street, Zamboanga City and via Video Conferencing.

PR No.	Item Description	Issues/Amendments/Updates/Clarifications to the Bidding Documents
24-0054	Supply & Delivery of Various Brass Fittings for Repair and Rehabilitation of Service Lines and Meter Stand Assy.	<ul style="list-style-type: none"> • QUERY: <i>I would like to ask lang for items nos. 1 & 2, if yung brass double adaptor and brass single adaptor, if compression type po ba or yung may clamp?</i> ANSWER: <u>Clamp type</u> • QUERY: <i>Another question po for item 4, brass safety valve 12mm, 5,000 pcs. Ask ko lang po kung ilan po yung irerequire nila na key? Kasi 5,000 pcs. po sya.</i> ANSWER: <u>100 Pcs.</u> • QUERY: <i>Sir, regarding po doon sa mga double adaptor, single adaptor, ang complete specs po ba nito is clamp type?</i> ANSWER: <u>Clamp type</u> • QUERY: <i>Sir, can we clarify for 1 to 11, all brass items is applicable only for male adaptor?</i> ANSWER: <u>Item no. 1 – clamp type; item no. 2 – male threaded; item no. 3 & 4 – female threaded; item no. 5 – male threaded; item no. 6 & 7 – female threaded; item no. 8 – male threaded; item nos. 9 & 10 – female threaded; & item no. 11 – male threaded</u>

		<ul style="list-style-type: none"> • Please find attached the <i>revised Schedule of Requirements and Technical Specifications</i>
24-0055	Supply & Delivery of Various G.I. Fittings for Repair and Rehabilitation of Service Lines and Meter Stand Assy.	<ul style="list-style-type: none"> • QUERY: <i>For the G.I. naman, sir, confirm ko lang yung items 23, 24, 25 & 27, plastic fittings po ito, sir?</i> <u>ANSWER: Yes Plastic</u> • QUERY: <i>Doon po sa schedule of requirements, kasi nakalagay po doon sa item no. 11 is 50 pcs., then doon po sa may delivery staggered, nakalagay sa item no. 11 is 30 pcs., ano po ba yung susundin namin na quantity, sir?</i> <u>ANSWER: 50 Pcs.</u> • QUERY: <i>Bale, sir, ang item 11, kabuoan po ang idedeliver doon sa second delivery?</i> <u>ANSWER: Yes</u> • QUERY: <i>Yun pong lahat ng items na may naka-note na plasson? Ito pong nakanote dito is ano po sya, made by plasson po ba o yung plasson is branded?</i> <i>Bale po, ang ano nya is full plastic sya, walang metal?</i> <u>ANSWER: Any kind of Plastic materials fittings po as long as ma fit sya sa mga existing P.E. pipes namin</u> • QUERY: <i>Doon po sa teflon tape, sir, anong thickness po kaya ito, sir?</i> <i>Anong point po kaya ito?</i> <u>ANSWER: atleast 3.5 mils</u> • QUERY: <i>P.E. Tubing wala naman po kayong brand na hinihingi, sir?</i> <i>SDR 11, ISO po?</i> <i>Tapos, black, sir?</i>

		<p><u>ANSWER: YES</u></p> <ul style="list-style-type: none">• Please find attached the <i>revised Schedule of Requirements and Technical Specifications</i>
--	--	--

For guidance and information of all concerned.


ATTY. VINCENT F. FERNANDEZ
Chairperson
Bids and Awards Committee

Posting date: May 6, 2024
Posted in the Phil-GEPS, ZCWD Website & Bid Bulletin