



Republic of the Philippines
ZAMBOANGA CITY WATER DISTRICT
Pilar Street, Zamboanga City

SUPPLEMENTAL/BID BULLETIN
ADDENDUM NO. 01 - 24-0114
Series of 2024

This SUPPLEMENTAL BID BULLETIN is issued to clarify, modify or amend items in the Bidding Documents for the below subject procurement in view of the Pre-Bid Conference last June 20, 2024, at the BAC Room, 3rd Floor, ZCWD Bldg., Pilar Street, Zamboanga City and via Video Conferencing.

PR No.	Item Description	Issues/Amendments/Updates/Clarifications to the Bidding Documents
24-0114	Supply & Delivery of PVC Materials for Proposed 200mmØ PVC Pipeline from Old Reservoir Distribution Line to the existing Luyahan Booster Station to improve water service at Lunzuran by maximizing Old Reservoir's Production	<ul style="list-style-type: none">• The type of PVC shall be Oriented PVC or PVC-O with ISO 16422 PN 16 standard, Bell/Spigot with rubber ring or fixed seal or its equivalent;• SLCC/Similar Project: Supply & Delivery of PVC Pipes & Fittings/Bends (w/c includes Unplasticized PVC or Oriented PVC);• The Procuring Entity's representative/ Inspection Committee shall inspect and test the items at the point of delivery to confirm the conformity to the contract specifications.

For guidance and information of all concerned.


ATTY. VINCENT F. FERNANDEZ
Chairperson
Bids and Awards Committee

Posting date: June 24, 2024
Posted in the Phil-GEPS, ZCWD Website & Bid Bulletin