



Republic of the Philippines
ZAMBOANGA CITY WATER DISTRICT
Pilar Street, Zamboanga City


SUPPLEMENTAL/BID BULLETIN
ADDENDUM NO. 01 – 24-0125
Series of 2024

This SUPPLEMENTAL BID BULLETIN is issued to clarify, modify or amend items in the issued Bidding Documents for the below subject procurement in view of the Pre-Bid Conference last July 09, 2024, at the BAC Room, 3rd Floor, ZCWD Bldg., Pilar Street, Zamboanga City and via Video Conferencing.

PR No.	Item Description	Issues/Amendments/Updates /Clarifications to the Bidding Documents
24-0125	Supply & Delivery of Submersible Pump for Proposed 200mmØ PVC Pipeline from Old Reservoir Distribution Line to the existing Luyahan Booster Station	<ul style="list-style-type: none">The brand name of the existing pumps/motors at the project site which are to be replaced as inquired by one of the prospective bidders during the pre-bid conference, are as follows: Existing Pump- Grundfos brand Existing Motor- Franklin brandAll Submersible Pumps/Motors to be supplied and delivered shall be 220-240 VAC with 3450 RPM Electric Motor

This shall form an integral part of the Bid Documents.

For guidance and information of all concerned.


ATTY. VINCENT F. FERNANDEZ
Chairperson
Bids and Awards Committee

Posting date: July 12, 2024
Posted in the Phil-GEPS, ZCWD Website & Bid Bulletin