



Republic of the *Philippines*
ZAMBOANGA CITY WATER DISTRICT
 Pilar Street, Zamboanga City

SUPPLEMENTAL/BID BULLETIN
ADDENDUM NO. 01 – 24-0179
Series of 2024

This SUPPLEMENTAL BID BULLETIN is issued to clarify, modify or amend items in the issued Bidding Documents for the below subject procurement in view of the Pre-Bid Conference last August 15, 2024, at the BAC Room, 3rd Floor, ZCWD Bldg., Pilar Street, Zamboanga City and via Video Conferencing and written Request for Clarification from TZ-E Trading sent via e-mail last August 15, 2024.

PR No.	Item Description	Issues/Amendments/Updates/Clarifications to the Bidding Documents
24-0179	Supply, Testing & Commissioning of Leak Detection Equipment	<ul style="list-style-type: none"> <p>• ZCWD Specifications: Under Real-Time Correlator a) Android Tablet</p> <p>Query: <i>What is the purpose of this?</i></p> <p>Reply from the End-user Unit: <u>Additional accessory.</u></p> <p>• ZCWD Specifications: Under Real-Time Correlator System: Maximum Distance</p> <p>Query: <i>What type of sensor are you using for these long distance correlation?</i></p> <p>Reply from the End-user Unit: <u>We will use Accelerometer since we have limited access for hydrants and will reduce the distance between the 2 sensors for more accurate correlation.</u></p> <p>• ZCWD Specifications: Under Electronic Ground Mic a) High performance sensor with cable ball</p> <p>Query: <i>As manufacturer standard</i></p> <p>Reply from the End-user Unit: <u>High performance sensor with cable ball or as manufacturer standard.</u></p> <p>• ZCWD Specifications: Under Electronic Ground Mic f) Ground plate + Isolating foam</p> <p>Query: <i>We are using different term of Ground Microphone as per Manufacturer</i></p>

		<p>Reply from the End-user Unit: <u>Ground plate + Isolating foam or as your manufacturer terms and standards.</u></p> <ul style="list-style-type: none"> • ZCWD Specifications: Under Electronic Ground Mic h.) Backpack <p>Query: <i>We are using a hard carrying case instead</i></p> <p>Reply from the End-user Unit: <u>Backpack or as per manufacturer standard.</u></p> <ul style="list-style-type: none"> • ZCWD Specifications: The Manufacturer should have a valid Cyber Essentials Certificate for cybersecurity <p>Query: <i>Is this certificate associated or in the same scope as ISO 27001?</i></p> <p>Reply from the End-user Unit: <u>ISO 27001 Certificate will suffice the requirement for Information Security Management System and Cyber Essentials for cyber security</u></p> <ul style="list-style-type: none"> • ZCWD Specifications: The Supplier must have a Type Approval Certificate for The correlator from NTC <p>Query: <i>We have EU Declaration of Conformity by the manufacturer as equivalent.</i></p> <p>Reply from the End-user Unit: <u>NTC or equivalent from supplier or manufacturer is acceptable.</u></p>
--	--	--

This shall form an integral part of the Bid Documents.

For guidance and information of all concerned.


ATTY. VINCENT F. FERNANDEZ
 Chairperson
 Bids and Awards Committee

Posting date: August 19, 2024
 Posted in the Phil-GEPS, ZCWD Website & Bid Bulletin