

Republic of the $oldsymbol{P}$ hilippines

ZAMBOANGA CITY WATER DISTRICT



Pilar Street, Zamboanga City

SUPPLEMENTAL/BID BULLETIN ADDENDUM NO. 01 - 24-0114 Series of 2024

This Addendum is issued to clarify, modify or amend items in the Bid Documents in view of the **Pre-Bid Conference** last **September 26**, **2024** via Video Conferencing. This shall form an integral part of the Bid Documents.

PR No.	Item Description	Issues/Amendments/Updates
		/Clarifications to the Bidding Documents
24-0114	Bidder's queries: Do a Bidder must need a Certificate from ISO regarding for PVC O Standard (ISO 16422)? Testing for ISO 16422 should be conducted in the Philippines only?	 The PVC-O Pipe Standard shall be ISO 16422 PN16 Standard. However, the Bidder is not required to have a Certificate from ISO regarding the PVC-O Standard. The Procuring Entity's representative/ Inspection Committee shall inspect and test the items at the point of delivery to confirm the conformity to the contract specifications pursuant to GCC Clause 4 of the Bidding Documents
	vii. White engraved marking < 0.15mm Our manufacturer recommends laser inkjet printing on PVC-O instead of denting the pipes with engraved markings. This is recommended to fully maximize the 50 years life span of the PVCO pipes, as dents in any types of pipes cause decrease in strength of the material over time of use.	The markings on the PVC-O Pipes may be engraved or laser inkjet printing.
	Query No. 2 - 200mmØ x 6.00m PVC Pipe, Bell/Spigot The standard length of PVCO pipe is 5.95m, which is slightly shorter by .05m to ensure that the pipes will not be damaged during the importation process. We understand that the quantity is computed based on the length of pipeline so we are amenable to increase the quantity to 126 lengths in order to make up for the slight variance of .05m per length.	 The pipe length requirement is 6.00-meter per 200mm PVC-O Pipe with a total pipeline length requirement of 750 meters. However, the bidder may offer & supply 5.95-meter commercial length per PVC pipe but with additional two (2) pipes (total of 127pcs) to commensurate the total pipeline length requirement. To simplify, below is the requirement: 125pcs - 200mmØ x 6.00m PVC Pipe OR 127pcs - 200mmØ x 5.95m PVC Pipe

For guidance and information of all concerned.

ATTY. VINCENT F. FERNANDEZ Chairperson

Bids and Awards Committee

Posting date: September 30, 2024 Posted in the Phil-GEPS, ZCWD Website & Bid Bulletin