



ZCWD SBAC SSTP SUPPLEMENTAL BID BULLETIN NO. 2024-03

Subject: PR No. 23-0204 – Proposed Design, Build, Testing & Commissioning of 4,000 Cu. M. per Day Sewage & Septage Treatment Plant

This ZCWD SBAC SSTP SUPPLEMENTAL BID BULLETIN is issued to clarify, modify, or amend items in the issued Bidding Documents for the above-subject procurement in view of the Pre-Bid Conference last September 19, 2024, at the Board Room, 2nd Floor, ZCWD Bldg., Pilar Street, Zamboanga City and via Zoom Video Conferencing.

This Supplemental is issued in line with Government Procurement Policy Board (GPPB) Circular 02-2018 (March 9, 2018), to **“minimize the occasions of bidders’ disqualification due to non-compliance with bidding requirements,”** particularly 4.2.2 which states, **“The BAC shall likewise discuss the common reasons of bidders’ disqualifications based on its experiences in previous procurement projects. Accordingly, the BAC shall present and explain the ways to prevent similar occasions of disqualification.”**

No.	GUIDELINES FOR ORAL PRESENTATION
1.	Each presenting bidder will be given a maximum of two (2) hours for their oral presentation, 1 ½ hours of which will be allotted for the question and answer. The presence of the designer during the oral presentation is highly encouraged to be able to resolve any technical questions that may arise.
2.	A face-to-face presentation is highly encouraged but not required to achieve a more dynamic discussion. Should the bidder opt for a face-to-face presentation, please coordinate with the BAC Secretariat at bac@zcwd.gov.ph . The bidder may also opt to present their design via an online platform.
3.	The presentation materials may include, but are not limited to, the following: company profile, facility design and specifications, construction approach and methods, facility features not specified in the Scope of Work, green and climate resiliency features of the facility design, and others that may enhance the merits of the technical proposals. Maps may be used if needed.
4.	The presentation must focus on the process and the technology offered, particularly on the mass balance of the proposed treatment process and the structural and architectural layout. It should explain how the present system, with a capacity of 4,000 cmd, will be expanded to 6,000 cmd. The presentation shall be comprised of the following:

	<ol style="list-style-type: none"> 1. Specify the range % of dry solid content in the sludge dewatering unit after dewatering; 2. Specify the sludge dewatering unit use; 3. Specify what are the flocculants aid use and consumption; 4. Specify the process involved per stage of treatment; 5. Provide the scheme/ process flow of the wastewater treatment process introduced; 6. Specify the raw wastewater data considered as influent in the initial design; 7. Specify the removal efficiency per stage of the process for Suspended solids, BOD₅, Phosphorus, Nitrogen, Ammonia, and Coliform: <table border="1" style="margin-left: 40px;"> <thead> <tr> <th>PROCESS</th> <th>Suspended Solids</th> <th>BOD₅</th> <th>Phosphorus</th> <th>Nitrogen</th> <th>Ammonia</th> <th>Coliform</th> </tr> </thead> <tbody> <tr> <td>Primary</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Secondary</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Tertiary</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Disinfection</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>	PROCESS	Suspended Solids	BOD ₅	Phosphorus	Nitrogen	Ammonia	Coliform	Primary							Secondary							Tertiary							Disinfection						
PROCESS	Suspended Solids	BOD ₅	Phosphorus	Nitrogen	Ammonia	Coliform																														
Primary																																				
Secondary																																				
Tertiary																																				
Disinfection																																				
5.	Bidders/presenters are requested to submit their presentation in PDF/PPT format to the BAC Secretariat at email bac@zcwd.gov.ph one (1) day before the scheduled oral presentation. The file must be password protected to ensure the integrity of the presentation, and the file may be opened only immediately before the time allotted for the bidder to present.																																			
6.	The presentation will use MS PowerPoint or PDF and should not exceed 30 minutes. Questions and answers will be allotted an hour and a half (1 ½). The presenter-bidder is expected to provide the answers during this allotted time.																																			

These clarifications shall form an integral part of the Bidding Documents. All items, conditions, and instructions to bidders specified in the Bidding Documents inconsistent with this Supplemental Bid Bulletin are hereby superseded and modified accordingly.


Important Notes:

It is the responsibility of the bidder to take steps to carefully examine all of the Bidding Documents. The Procuring Entity shall not assume any responsibility regarding erroneous interpretations or conclusions by the prospective or eligible bidder out of the data furnished by the Procuring Entity.

A prospective eligible bidder must be responsible for having: 1. Taken steps to carefully examine all of the bidding documents; 2. Acknowledged all conditions, local or otherwise, affecting the implementation of the contract; 3. Made an estimate of the facilities available and needed for the contract to be bid, if any; and 4. Complied with his responsibility that it shall be the responsibility of all those who have properly secured the bidding documents to inquire and secure supplemental/bid bulletins that may be issued by the BAC (Government Procurement Manual Volume 3).

Failure to observe any of the above responsibilities shall be at the risk of the prospective bidder concerned. The Procuring Entity shall not be responsible for any erroneous interpretation or conclusions by the prospective or eligible bidders of the data it furnished (Government Procurement Manual Volume 3).

For guidance and information of all concerned.


ATTY. VINCENT F. FERNANDEZ
Chairperson
Bids and Awards Committee

Posting date: September 23, 2024
Posted in the Phil-GEPS, ZCWD Website & Bid Bulletin