



Republic of the *Philippines*
ZAMBOANGA CITY WATER DISTRICT
Pilar Street, Zamboanga City

SUPPLEMENTAL/BID BULLETIN
ADDENDUM NO. 01 – 24-0226
Series of 2024

This SUPPLEMENTAL BID BULLETIN is issued to clarify, modify or amend items in the issued Bidding Documents for the below subject procurement in view of the Pre-Bid Conferences last November 19, 2024, at the BAC Room, 3rd Floor, ZCWD Bldg., Pilar Street, Zamboanga City and via Video Conferencing.

PR No.	Item Description	Issues/Amendments/Updates/Clarifications to the Bidding Documents
24-0226	Supply, Installation, Testing & Commissioning of 1 Ton Chlorine Cylinder Tank Weighing Scale for use at Water Treatment Plant	<ul style="list-style-type: none">• Framing / Materials: Stainless Steel or Carbon Steel with anti-corrosion finish• Digital Monitor shall be revised from 6" to 8" to <u>4" to 8"</u>• Delivery Point shall be at the <u>ZCWD Water Treatment Plant</u> instead of Property Section, Motorpool• Please find attached the revised Schedule of Requirements and Technical Specifications reflecting the changes mentioned above• Indicative Annual Procurement Plan Approved by the Board for year <u>2025</u> instead of 2021

This shall form an integral part of the Bid Documents.

For guidance and information of all concerned.


ATTY. VINCENT F. FERNANDEZ
Chairperson
Bids and Awards Committee

Posting date: November 22, 2024
Posted in the Phil-GEPS, ZCWD Website & Bid Bulletin

Section VI. Schedule of Requirements

The delivery schedule expressed as weeks/months stipulates hereafter a delivery date which is the date of delivery to the project site.

Item Number	Description	Quantity	Total	Delivered, Weeks/Months
1	Supply, Installation, Testing & Commissioning of:	1 set		
	1 Ton Chlorine Cylinder Tank Weighing Scale with digital monitor & complete accessories with the following:			
	Specifications:			
	1. Capacity (Range) – 2,000kg to 2,200kg			
	2. Readability – 0.5kg to 1kg			
	3. Framing/Materials: Stainless Steel or Carbon Steel with Anti-Corrosion Finish			
	4. Accuracy – 0.1% to 0.3%			
	5. Power Requirements – 220-230VAC, 60Hz (w/ included power adapter, Rechargeable battery approx. 12 to 24 hrs use			
	6. Operating Temperature – 20deg.C to 40 deg.C			
	7. Overload Condition – 100% to 102%			
	8. Display Speed – 0.5 to 1.0 second (adjustable)			
	9. Digital Monitor – 4” to 8” color touchscreen, visually driven user interface, user programmable extended accuracy parameters, multiple screen format choices, battery backup			
	10. Other Options – Scada-Ready, RS-232, USB, Ethernet, Wi-Fi, 4-20mA Analog output, label and ticket printers, Barcode scanner, programmable setpoints for filling, mixing and monitoring, Email Alerts, Rechargeable battery			
	Delivery Period: 60 calendar days upon receipt of Purchase Order			
	Delivery Point: ZCWD Water Treatment Plant, Pasonanca, Z.C.			

Technical Specifications

Item	Specification	Statement of Compliance
		<p><i>[Bidders must state here either “Comply” or “Not Comply” against each of the individual parameters of each Specification stating the corresponding performance parameter of the equipment offered. Statements of “Comply” or “Not Comply” must be supported by evidence in a Bidders Bid and cross-referenced to that evidence. Evidence shall be in the form of manufacturer’s un-amended sales literature, unconditional statements of specification and compliance issued by the manufacturer, samples, independent test data etc., as appropriate. A statement that is not supported by evidence or is subsequently found to be contradicted by the evidence presented will render the Bid under evaluation liable for rejection. A statement either in the Bidder's statement of compliance or the supporting evidence that is found to be false either during Bid evaluation, post-qualification or the execution of the Contract may be regarded as fraudulent and render the Bidder or supplier liable for prosecution subject to the applicable laws and issuances.]</i></p>
1	1 set Supply, Installation, Testing & Commissioning of:	
	1 Ton Chlorine Cylinder Tank Weighing Scale with digital monitor & complete accessories with the following:	
	Specifications:	
	1. Capacity (Range) – 2,000kg to 2,200kg	
	2. Readability – 0.5kg to 1kg	
	3. Framing/Materials: Stainless Steel or Carbon Steel with Anti-Corrosion Finish	
	4. Accuracy – 0.1% to 0.3%	
	5. Power Requirements – 220-230VAC, 60Hz (w/ included power adapter, Rechargeable battery approx. 12 to 24 hrs use	
	6. Operating Temperature – 20deg.C to 40 deg.C	
	7. Overload Condition – 100% to 102%	
	8. Display Speed – 0.5 to 1.0 second (adjustable)	

	9. Digital Monitor – 4” to 8” color touchscreen, visually driven user interface, user programmable extended accuracy parameters, multiple screen format choices, battery backup	
	10. Other Options – Scada-Ready, RS-232, USB, Ethernet, Wi-Fi, 4-20mA Analog output, label and ticket printers, Barcode scanner, programmable setpoints for filling, mixing and monitoring, Email Alerts, Rechargeable battery	