



Republic of the *Philippines*
ZAMBOANGA CITY WATER DISTRICT
Pilar Street, Zamboanga City

SUPPLEMENTAL/BID BULLETIN
ADDENDUM NO. 01 – 25-0043
Series of 2025

This ADDENDUM/SUPPLEMENTAL BID BULLETIN is issued to clarify, modify or amend items in the issued Bidding Documents for the below subject procurement in view of the Pre-Bid Conference last March 25, 2025, at the BAC Room, 3rd Floor, ZCWD Bldg., Pilar Street, Zamboanga City and via Video Conferencing.

PR No.	Item Description	Issues/Amendments/Updates/Clarifications to the Bidding Documents
25-0043	Supply & Delivery of 4,280 bags of Aluminum Sulfate – 17%±1% for water treatment use	<ol style="list-style-type: none">1. Must submit 1 kg sample and results of analysis during opening of bids.2. Results of Analysis must be done by an ISO certified or any DOH accredited testing laboratory and must indicate the following;<ol style="list-style-type: none">a. Name and address of Supplierb. Brand of Aluminum Sulfate offeredc. Results of Aluminum as Alumina (% w/w Al₂O₃)d. Certificate of analysis must have been conducted at least 8 (eight) months prior to bid opening.3. Brand of Aluminum Sulfate subjected to laboratory analysis must be the same brand to be delivered at the point of delivery.4. Packaging must indicate the following;<ol style="list-style-type: none">a. Name of goods.b. Name of Supplier or Manufacturerc. Net weight in kilograms (kg)d. Alumina content in percent (%)

This shall form an integral part of the Bid Documents.

For guidance and information of all concerned.


ATTY. VINCENT F. FERNANDEZ
Chairperson
Bids and Awards Committee

Posting date: March 31, 2025
Posted in the Phil-GEPS, ZCWD Website & Bid Bulletin