SUPPLEMENTAL/BID BULLETIN ADDENDUM NO. 01 – 25-0070 Series of 2025

Subject: PR No. 25-0070 – Supply & Delivery of 17,535 pcs. Water Meter (15 mm) – Single Jet for Replacement of Aging Water Meters and New Tapping

This SUPPLEMENTAL BID BULLETIN is issued to clarify, modify, or amend items in the issued Bidding Documents for the above-subject procurement in view of the **Pre-Bid Conference** last **April 24, 2025**, at the BAC Room, 3rd Floor, ZCWD Bldg., Pilar Street, Zamboanga City and via Zoom Video Conferencing.

Particulars	Issues/Amendments/Updates /Clarifications to the Bidding Documents Instruction to Bidders (ITB) Clause 5.3 of the Bid Data Sheet For this purpose, contracts similar to the Project shall be: a. Supply & delivery of Water Meter		
Instruction to Bidders (ITB) Clause 5.3 of the Bid Data Sheet For this purpose, contracts similar to the Project shall be: a. Supply & delivery of 15mm Single Jet Water Meter			
1 st Delivery: 4000 pcs. – 35 calendar days from receipt of NTP	1 st Delivery: 4000 pcs. – 15 calendar days from receipt of NTP		
Inspection and Acceptance	The following inspections and tests shall be conducted based on the contracted volume of water meters: 1. A random selection of water meters, based on the required percentage of the total contracted quantity, shall undergo bench testing to determine accuracy and compliance with acceptable testing standards. 2. The results from the tested sample shall serve as the basis for issuance of Receiving Report for the delivered water meters following the delivery schedule (staggered delivery). The issuance of the Receiving Report and processing of payment will proceed only if the tested meters fall within acceptable accuracy standards. 3. The remaining water meters will also be subjected to bench testing at the Water Meter Laboratory Shop.		



Republic of the Philippines ZAMBOANGA CITY WATER DISTRICT

Pilar Street, Zamboanga City



4. All water meters found to be non-compliant, defective, or non-functioning, and those that do not meet acceptable testing standards, shall be replaced by the supplier at their own expense.

INITIAL	TESTIN	G REC	UIREME	NTS
SIZE	VOLUME(QTY)			%
12MM-15MM	1		30,000	10%
25MM	1		100	100%
19MM	1		100	100%
38MM	1	TO	100	100%
50MM	1		100	100%
75MM	1		100	100%
100MM	1		100	100%

Replacement of Failed, Non-Functioning and/or Defective Water Meters For failed, non-functioning and/or defective water meters returned, the serial number for the replacement water meter/s does not need to be of the same serial number of the water meter to be replaced. However, the serial number for the replacement shall follow the format required (Format: WD-25- followed by 6 digits) and should not duplicate any of the serial numbers in the series as required in the purchase request.

These clarifications shall form an integral part of the Bidding Documents. All items, conditions, and instructions to bidders specified in the Bidding Documents inconsistent with this Supplemental Bid Bulletin are hereby superseded and modified accordingly.

For guidance and information of all concerned.

Chairperson

Bids and Awards Committee

Posting date:

Posted in the Phil-GEPS, ZCWD Website & Bid Bulletin