



Republic of the Philippines
ZAMBOANGA CITY WATER DISTRICT
Zamboanga City



TECHNICAL SPECIFICATIONS/REQUIREMENTS FOR P.E. TUBING

I. Pipes shall be marked (engraved) with the following information:

- Manufacturer's name
- Brand
- Nominal outside diameter, SDR Rating & Pressure rating
- Batch Number
- Year Manufactured
- The word "WATER" at intervals not more than 1 meter apart

Prepared by:


MARK BENEDICT C. REYES
OIC-PAMD