



SUPPLEMENTAL/BID BULLETIN
ADDENDUM NO. 01 – 25-0037
Series of 2025

Subject: PR No. 25-0037 – Supply & Delivery of Various Air Release Valve for Maintenance of Transmission Lines

This **SUPPLEMENTAL BID BULLETIN** is issued to clarify, modify, or amend items in the issued Bidding Documents for the above-subject procurement in view of the **Pre-Bid Conference** last **June 5, 2025**, at the BAC Room, 3rd Floor, ZCWD Bldg., Pilar Street, Zamboanga City and via Googlemeet Video Conferencing.

| Particulars | Issues/Amendments/Updates /Clarifications to the Bidding Documents |
|-------------|--|
| Standards | Manufacturing standards meets BS EN 1074-4, AWWA C512 |
| Threaded | All connections are either threaded or flange type For flange , flange drilling and dimension must meets BS EN 1092, BS EN 558 and ANSI flange. |

These clarifications shall form an integral part of the Bidding Documents. All items, conditions, and instructions to bidders specified in the Bidding Documents inconsistent with this Supplemental Bid Bulletin are hereby superseded and modified accordingly.

For guidance and information of all concerned.


ATTY. VINCENT F. FERNANDEZ
Chairperson
Bids and Awards Committee

Posting date: **June 10, 2025**
Posted in the Phil-GEPS, ZCWD Website & Bid Bulletin